

WAC 246-215-05260 Location and placement of backflow prevention device (2009 FDA Food Code 5-204.12). A backflow prevention device must be located so that it can be serviced and maintained.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05260, filed 1/17/13, effective 5/1/13.]